## Certificate of Calibration



Certificate #: 1592965 Purchase Order #: 4373



Calibration Performed By:

PROBATA CORPORATION 14600 Metro Plaza Blvd. PO BOX 4090 (73083) Edmond, OK 73013

(405) 607-4813 / FAX (405) 607-4832

For:

ILLIANA INSTRUMENTATION SERVICE

1831 GOVERT DRIVE

SCHERERVILLE IN,46375

onsite:

**Equipment Information** 

Manufacturer: CONSOLIDATED DEVICES

Model:

4002-I-DTT

Description:

TORQUE TRANSDUCER

Range/Grad:

40.0 - 400.0 IN-LB

Temp./RH: Cal Date:

68.0 deg F, / 32.0 % rH

1/23/2023

Asset Number: 1724

Serial Number:

Department:

Location:

User:

UNK

Cal Procedure:

33K6-4-3176-1

062188-143

Revision Date: 1/31/2022

Calibration Results

Received Condition:

**MEASURED VALUES < LIMITS** 

Returned Condition: AS FOUND/AS LEFT DATA IS THE SAME

Notes:

## Probata Calibration Standards Used for Certification

Asset #	Manufacturer	Model #	Description	Last Cal.	Cal. Due Date
0502	TROEMNER	WEIGHT SET HANGER (10PC	) WEIGHT SET HANGER-(10 PC)-CLASS F	4/20/2022	4/20/2023
1041	TROEMNER	WEIGHT SET	WEIGHT SET (29 PC)-CLASS 6	4/20/2022	4/20/2023
1188	CDI	2000-152-0	TORQUE BUTTERFLY WHEEL	8/2/2021	8/2/2023

Probata certifies that the above instrument meets or exceeds specifications as stated in the referenced procedure (unless otherwise noted). It has been calibrated using measurement standards traceable to the International System of Units (SI), through the National Institute of Standards and Technology (NIST) or other National Metrology Institutes participating in the CIPM-MRA or ratiometric techniques or natural physical constants. This calibration complies with ANSI/NCSL Z540-1-1994, ISO 17025 and meets the quality standards set forth in ISO 9001. This document applies only to the calibration of the item described.

No statement of conformity with specifications is made or implied on this certificate. However, measurement results are reviewed, where applicable, to establish where any measurement result exceeded the manufacturer's specifications.

ALL RESULTS MAY BE INVALID BASED ON CONDITIONS AS RECEIVED. THIS CERTIFICATE MAY NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF PROBATA CORPORATION

Approved By:

JON SCRUGGS

Calibrated By:

PETER ZOLLA

QUALITY TECHNICIAN

CALIBRATION TECHNICIAN

FRM-1601 Rev. May 2018

Page 1 of 1

Issue Date: 1/23/2023



## **Equipment Information**

## CDI Model 4002-I-DTT Digital Torque Tester Range: 40 to 400 in/lbs Calibration Results

Parameter Tested Nominal		As Fo	ound As Left	Low Limit High Limit		EU (k=2)						
Clockwise Torque Verification												
10" Wheel Wei	ght Applied											
4 lbs. Applied	39.957 ii	alb 39.9	92 39.92	39.76	40.16	0.04	inlb					
8 lbs. Applied	79.914 in	ılb 79.8	79.89	79.51	80.31	0.08	inlb					
16 lbs. Applied	159.828 in	ılb 159	.5 159.5	159.03	160.63	0.16	inlb					
24 lbs. Applied	239.742 in	ılb 239	.4 239.4	238.54	240.94	0.24	inlb					
32 lbs. Applied	319.657 in	ılb 319	.4 319.4	318.06	321.26	0.32	inlb					
40 lbs. Applied	399.571 in	ılb 398	.7 398.7	397.57	401.57	0.40	inlb					
Counterclockwise Torqu	e Verification											
10" Wheel Wei	ght Applied											
4 lbs. Applied	39.957 ir	ilb 39.9	39.94	39.76	40.16	0.02	inlb					
8 lbs. Applied	79.914 ir	ılb 79.7	70 79.70	79.51	80.31	0.05	inlb					
16 lbs. Applied	159.828 ir	ılb 159	.5 159.5	159.03	160.63	0.10	inlb					
24 lbs. Applied	239.742 ir	ılb 239	.4 239.4	238.54	240.94	0.14	inlb					
32 lbs. Applied	319.657 ir	ilb 319	.0 319.0	318.06	321.26	0.19	inlb					
40 lbs. Applied	399.571 ir	lb 399	.2 399.2	397.57	401.57	0.24	inlb					

Manufacturer Stated Accuracy: ±0.5% of Reading from 10% to 100% of Rated Capacity

Measurement results that are greater than limits of error are indicated by an "!"

The above measurement uncertaintites represent expanded uncertainties expressed at approximately the 95% confidence level using a coverage factor of k=2

FRM-1601B rev. 11-17 Page 1 of 1